



Date: 3/31/20  
Subject: Field Applied 2-Hour Rated Fire Wrap

To whom it may concern,

DuraVent DCL [*Security Chimneys SCL*] (single wall) holds a UL 1978 Standard for Safety for Grease Ducts listing. It is acceptable to apply a field wrap to achieve a 2-hour fire-resistant rated shaft. The wrap must have been tested and comply as per ASTM E 2336 Standard Test Methods for Fire Resistive Grease Duct Enclosures. The wrap must also be two layers with overlapping joints installed per the wrap manufacturers installation instructions.

DuraVent product has an industry leading limited lifetime warranty that is not impacted when field applied wrap is applied as per the manufacturer's instructions.

Regards,

Eric Dufour, Eng.  
VP Innovation & Engineering